

# Attestation of Conformity

**Attestation No:** **SHA-AoC-230023**

**Applicant Name & Address:** Afore New Energy Technology (Shanghai) Co., Ltd.  
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China.  
201112

**Factory Name & Address:** Afore New Energy Technology (Shanghai) Co., Ltd.  
Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China.  
201112

**Product Description:** Hybrid inverter / AC Coupled inverter

**Brand Name:** Afore

**Model:** AF1K-SL-0, AF1.5K-SL-0, AF2K-SL-0, AF2.5K-SL-0, AF3K-SL-0, AF3.6K-SL-0,  
AF4K-SL-0, AF4.6K-SL-0, AF5K-SL-0, AF5.5K-SL-0, AF6K-SL-0  
AF1K-SL-1, AF1.5K-SL-1, AF2K-SL-1, AF2.5K-SL-1, AF3K-SL-1, AF3.6K-SL-1  
AF3K-SL, AF3.6K-SL, AF4K-SL, AF4.6K-SL, AF5K-SL, AF5.5K-SL, AF6K-SL  
AF4K-SLP, AF4.6K-SLP, AF5K-SLP, AF5.5K-SLP, AF6K-SLP

**Characteristics:** See appendix for details

**Standards:** EN IEC 61000-6-1: 2019; EN IEC 61000-6-3: 2021;  
EN 61000-3-12: 2011; EN IEC 61000-3-11: 2019

**EU Directive:** the EMC Directive 2014/30/EU

**Test Report No:** 230601235SHA-001

**Issued by:** Intertek Testing Services Ltd. Shanghai  
West Area, 2nd Floor, No. 707, Zhangyang Road, China (Shanghai)  
Pilot Free Trade Zone, Shanghai, P. R. China

**Issue date:** 2023-12-20

This is to attest that the Technical Construction File for the product listed above has been evaluated against the Essential Safety Requirements of Annex I of the EMC Directive (2014/30/EU). This Attestation can be used in support of the Manufacturers Declaration of Conformity on affixing the CE marking. Product conformity to CE marking is not assured until all other applicable EU Directives are met in full.

Signature



Name: Gary Hu



## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

Ratings & Principle Characteristics:

Specifications table					
Model	AF1K-SL-1	AF1.5K-SL-1	AF2K-SL-1	AF2.5K-SL-1	AF3K-SL-1
<b>PV input</b>					
P <sub>pv</sub> Max(W)	1500	2300	3000	3800	4500
V <sub>max</sub> PV (Vdc) (absolute Max.)	550	550	550	550	550
I <sub>sc</sub> PV (absolute Max.) (A)	26	26	26	26	26
Number MPP trackers	1	1	1	1	1
Number input strings	1	1	1	1	1
Max. PV input current / strings (A)	18.5	18.5	18.5	18.5	18.5
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
V <sub>dc</sub> range @ full power (Vdc)	80-500	90-500	120-500	150-500	170-500
<b>Battery (charge/discharge)</b>					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	25	40	50	63	80
Max charge/discharge Power(W)	1000	1500	2000	2500	3000
<b>AC Grid (input and output)</b>					
Normal AC Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Normal AC Current (A)	4.4	6.6	8.7	10.9	13.1
Max. cont. input/output current (A)	5	7	10	12	14
Rated Power(W)	1000	1500	2000	2500	3000
Rated Apparent Power (VA)	1000	1500	2000	2500	3000
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor (adjustable)	1.0(-0.8~ +0.8)				
<b>AC Load output (stand alone)</b>					
Normal Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Nominal Current(A)	4.4	6.6	8.7	10.9	13.1
Max. cont. current (A)	5	7	10	12	14
Max. cont. Power (W)	1000	1500	2000	2500	3000
Rated Apparent Power (VA)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor	1.0				
<b>Others</b>					
Ingress protection (IP)	IP65				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (PV-AC-BAT)				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Firmware	1.01				

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

### Ratings & Principle Characteristics:

Specifications table				
Model	AF3.6K-SL-1	AF3K-SL	AF3.6K-SL	AF4K-SL
<b>PV input</b>				
P <sub>pv</sub> Max(W)	5400	4500	5400	6000
V <sub>max</sub> PV (Vdc) (absolute Max.)	550	550	550	550
I <sub>sc</sub> PV (absolute Max.) (A)	26	26 x 2	26 x 2	26 x 2
Number MPP trackers	1	2	2	2
Number input strings	1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	210-500	90-500	110-500	120-500
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	3600	3000	3600	4000
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	15.7	13.1	15.7	17.4
Max. cont. input/output current (A)	17	14	17	19
Normal Power (W)	3600	3000	3600	4000
Rated Apparent Power (VA)	3600	3000	3600	4000
Max. cont. input/output Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor(adjustable)	1.0(-0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	15.7	13.1	15.7	17.4
Max. cont. current (A)	17	14	17	19
Max. cont. Power (W)	3600	3000	3600	4000
Rated Apparent Power (VA)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware	1.01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

Ratings & Principle Characteristics:

Specifications table				
Model	AF4.6K-SL	AF5K-SL	AF5.5K-SL	AF6K-SL
<b>PV input</b>				
P pv Max(W)	6900	7500	8300	9000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550
Isc PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	130-500	150-500	160-500	170-500
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	4600	4800	4800	4800
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	20	21.8	24	26.1
Max. cont. input/output current (A)	22	23	26	28
Normal Power (W)	4600	5000	5500	6000
Rated Apparent Power (VA)	4600	5000	5500	6000
Max. cont. input/output Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	20	21.8	24	26.1
Max. cont. current (A)	22	23	26	28
Max. cont. Power (W)	4600	5000	5500	6000
Rated Apparent Power (VA)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV-AC-BAT)			
Oversvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware	1.01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

Ratings & Principle Characteristics:

Specifications table					
Model	AF4K-SLP	AF4.6K-SLP	AF5K-SLP	AF5.5K-SLP	AF6K-SLP
<b>PV input</b>					
P pv Max(W)	6000	6900	7500	8300	9000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550	550
Isc PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	2	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	120-500	130-500	150-500	160-500	170-500
<b>Battery (charge/discharge)</b>					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	120	120	120	120	120
Max charge/discharge Power(W)	4000	4600	5000	5500	6000
<b>AC Grid (input and output)</b>					
Normal AC Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Normal AC Current (A)	17.4	20	21.8	24	26.1
Max. cont. input/output current (A)	19	22	23	26	28
Rated Power(W)	4000	4600	5000	5500	6000
Rated Apparent Power (VA)	4000	4600	5000	5500	6000
Max. cont. Power (W)	4000	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4000	4600	5000	5500	6000
Power factor (adjustable)	1.0( -0.8~ +0.8)				
<b>AC Load output (stand alone)</b>					
Normal Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Nominal Current(A)	17.4	20	21.8	24	26.1
Max. cont. current (A)	19	22	23	26	28
Max. cont. Power (W)	4000	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4000	4600	5000	5500	6000
Power factor	1.0				
<b>Others</b>					
Ingress protection (IP)	IP65				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Oversvoltage category	OVC III (AC Main), OVC II (PV)				
Firmware	1.01				

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

### Ratings & Principle Characteristics:

Specifications table				
Model	AF1K-SL-0	AF1.5K-SL-0	AF2K-SL-0	AF2.5K-SL-0
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	25	40	50	63
Max charge/discharge Power(W)	1000	1500	2000	2500
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	6.6	8.7	10.9
Max. cont. input/output current (A)	5	7	10	12
Rated Power(W)	1000	1500	2000	2500
Rated Apparent Power (VA)	1000	1500	2000	2500
Max. cont. Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor (adjustable)	1.0(-0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	4.4	6.6	8.7	10.9
Max. cont. current (A)	5	7	10	12
Max. cont. Power (W)	1000	1500	2000	2500
Rated Apparent Power (VA)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main)			
Firmware	1.01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

### Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-SL-0	AF3.6K-SL-0	AF4K-SL-0	AF4.6K-SL-0
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	120	120
Max charge/discharge Power(W)	3000	3600	4000	4600
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	13.1	15.7	17.4	20
Max. cont. input/output current (A)	14	17	19	22
Normal Power (W)	3000	3600	4000	4600
Rated Apparent Power (VA)	3000	3600	4000	4600
Max. cont. input/output Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor(adjustable)	1.0(-0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	13.1	15.7	17.4	20
Max. cont. current (A)	14	17	19	22
Max. cont. Power (W)	3000	3600	4000	4600
Rated Apparent Power (VA)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main)			
Firmware	1.01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.

## APPENDIX: Attestation of Conformity

This is an Appendix to Attestation of Conformity Number: SHA-AoC-230023

### Ratings & Principle Characteristics:

Specifications table				
Model	AF5K-SL-0	AF5.5K-SL-0	AF6K-SL-0	
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	120	120	120	
Max charge/discharge Power(W)	5000	5500	6000	
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24	26.1	
Max. cont. input/output current (A)	23	26	28	
Normal Power (W)	5000	5500	6000	
Rated Apparent Power (VA)	5000	5500	6000	
Max. cont. input/output Power (W)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	21.8	24	26.1	
Max. cont. current (A)	23	26	28	
Max. cont. Power (W)	5000	5500	6000	
Rated Apparent Power (VA)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Oversvoltage category	OVC III (AC Main)			
Firmware	1.01			

This Attestation is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Attestation. Only the Client is authorized to permit copying or distribution of this Attestation.. The observations and test/inspection results referenced in this Attestation are relevant only to the sample tested/inspected. This Attestation by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. This Attestation is not accredited under a ISO IEC 17065 accreditation.